


## Safety Drain Tray


### NOTES

- Refer to indoor unit dimension page for specification of drain connectors.
- Test condensate drain installation to ensure that water flows freely and does not leak. Also check that the drain tray does not overflow.
- All drawings are for illustration purposes only. Actual unit may vary depending on the model.

### Suggested Minimum Slope To Ensure Correct Drainage



### Suggested P-Trap Connection With Limited Height Clearance



### Suggested P-Trap Connection With Long Drain Runs

